



Swedish Institute for Technical
Approval in Construction



English version

1 (2)

20 February 2002

Reg. No. T 000 375-01

TYPE APPROVAL CERTIFICATE 0363/93

and decision on production control in accordance with §§ 18-20 of the Act (1994:847) on Technical Property Requirements for Construction Works, etc., BVL

KEY WORD: FIRE PROTECTION
Wooden doors, fire-resistance grade EI

BSAB X2

VINDSTRAPPA LEX 60 EI 30

- Issued to** Samhall AB, Hantverkarsvägen 2, 861 36 Timrå, tel; +46 60 - 50 41 20, fax; +46 60 - 50 41 30, hemsida; www.midmade.com, e-mail; info@midmade.com, org.nr; 556448-1397.
- Product** VINDSTRAPPA LEX 540/700, wooden ceiling hatch insulated with rock wool and glass wool, maximum width x height, 700x1130 mm, EI 30.
The ceiling hatch is equipped with a folding out wooden ladder.
- Intended use** Fire separating ceiling hatch in buildings.
- Trade name** LEX 60
- Approval** The product meets the requirements in 2 § 2 BVL, with respect to and on the conditions stated in this certificate, and is therefore approved with regard to the requirements in the following section of the Building Regulations of the National Board of Housing, Building and Planning (BBR):
Fire-resistant grade EI 30 5:22
- Associated documents** Assembly Instruction for MidMade Vindstrappa LEX dated September 1993
- Control** Production control is to be performed in accordance with instructions for control dated 2000-02-02 with registration number 210-00-0063, and be supervised by an independent third party body, SP (Swedish National Testing and Research Institute).
The inspection on the building site will ensure that the correct product has been delivered, by identifying by means of the marking. That will further ensure that workmanship and application of the product complies with the specifications in the associated documents.

SITACSwedish Institute for Technical
Approval in Construction

2 (2)

4 September 1998

Certificate No. 0363/93

Control At the inspection shall be verified that the product has been accompanied by a certificate issued by the manufacturer (*manufacturer's warranty*) which ensures that the delivered product complies with specifications in the type approval and the production control.

Manufacturer The prescriptions for production control are valid for following site of manufacture:
Samhall AB, Timrå

Marking Products are to be marked at the factory. The marking consists of a label on each delivered ceiling hatch and includes:

Manufacturer and manufacturing site	Samhall AB, Timrå
The National Board of Housing, Building and Planning's registered trademark	T
SITAC's accreditation number	SITAC 1422
Product type designation	LEX 60
Fire-resistant grade	EI 30
The number of the Type Approval Certificate	0363/93
Serial number and week produced	serial number
Inspection body	SP

Basis for approval Report No. 92 R12236 A from the Swedish National Testing and Research Institute (SP).

<i>Drawing no.</i>	<i>dated</i>
100461D	94-06-25
100462E	94-10-05
100464D	96-02-12
100485B	94-09-12

Comments The type approval only comprises the fire technical properties of the ceiling hatch.

Assembly instruction is to be attached to every ceiling hatch delivered.

This certificate supersedes previous certificate with the same number dated 4 September 1999. Reg. No. 81-0481/98.

Period of validity This approval is valid until 20 February 2007.


Tor Bakke


Björn Holgersson